

**Accurate Testing Labs, LLC**

7950 Meadowlark Way  
Coeur d'Alene, ID 83815  
Phone (208) 762 8378 Fax (208) 762 9082

**STATE OF IDAHO**  
**Drinking Water Coliform Bacteria Analysis**  
**Report**Order No.: **2016100440 1**

Report Date: 10/28/16

H2O Well Service  
582 W Hayden Ave  
Hayden Lake , ID 83835

Water System: Roberta Robinson  
Location: Well - Lot 10, Starlight Rd, D0033898  
County: Kootenai  
Collected by: H2O Well  
Sample Type: C-Construction

Date Collected: 10/27/2016  
Time Collected: 13:00

Date Received: 10/27/2016  
Time Received: 15:14

Method	Analyte	Result	Analysis Date	Analyst
9223B-PA	E. Coli	Absent	10/28/16	MT
9223B-PA	Total Coliform	Absent	10/28/16	MT

**Notes:**

IF YOUR RESULT IS "ABSENT": The absence of coliform bacteria indicates that your water is not contaminated with coliform bacteria.

IF YOUR RESULT IS "PRESENT": The presents of coliform bacteria means that your water is contaminated, and may contain disease causing organisms. Contaminated water should not be used for drinking water.

If coliform bacteria are present, an additional test has been run for Escherichia coli bacteria. The result for this test is also reported as being present or absent.