Boulder County Window and Door Replacement Submittal Form

Please complete ALL the values for each window to be installed listed below.

List the materials of window frame and sash construction: Vinyl clad wood



REVIEWED For Code Compliance Sep 30 2024 AV BOULDER COUNTY BUILDER COUNTY BUILDER SAME From Name Basement patio door	Floor Level (basement, first, second, etc.)	Window Type (casement, slider, awning, etc.) Patio door	Proximity to Door(s) INCHES	Window Opening Sill Height measured above finished floor INCHES	Top of glazing measured above finished floor INCHES	Window Size (W x H)				Existing window	Maximum U-Factor for: glazed doors 0.30
						Width INCHES 94 1/2"	Height INCHES 79 1/2"	Egress Window? (X) if yes	Safety Glazing (X) if yes	opening to be enlarged or altered? (X) if yes	windows 0.30 skylights 0.43 U-factor

- If a room has a closet that opens directly to the room, it WILL be considered a bedroom and WILL require an Emergency Escape and Rescue Opening compliant with IRC Section R311.
- New or enlarged window and door opening(s) WILL require signed and sealed engineered design by a Colorado licensed design professional with structural information.
- Cutting the existing foundation requires a signed and sealed engineered design by a Colorado licensed design professional.
- Bay or bow window units placed in an existing or new opening require a site plan.
- Safety Glazing as required per IRC Section R308 and R308.4.
- If bedroom egress is provided by an exterior door make this note in the Opening Location Room Name of the corresponding line.