

Documentation of Closure

by
Underground Services Co. LLC
Raleigh, N.C.

In accordance with the recommended procedures of the N.C. Dept. Environment and Natural Resources, Underground Storage Tank Division, we present the following documentation of closure for:

Address of tank ; 107 Ledge, Chapel Hill, N.C.

Classification:..... residential underground heating oil storage tank
Tank dimensions & capacity..... 42" x 92" (560 gals)
Depth of tank.....23"
Date tank pumped.....2/20/11
Date tank filled:.....2/21/11
Tank location:.....left side yard
Orientation.....N/S
Type tank:.....single wall 14 ga. metal w/welded seams
Regulated tankno (per NC Admin. Code, title 15A subchapter 2N)

This documentation provides that:

All work performed on this tank was in accordance with recommendations and procedures set forth by the N.C. Dept. Environmental and Natural Resources, UST Section.

This tank qualifies for closure in place due to its proximity to a residential structure and its classification as non regulated.

Following NCDENR guidelines, visual and odor checks were made to the soil during excavation to the tank top prior to filling and **no** evidence of leakage was present.


Contents of tank pumped and removed for processing by FCC Environmental Services

Tank filled with NCDENR approved inert solid material: polyurethane foam
(350 gm/gal. density) applied by N. Carter, TCA # 0090

Vent and fill pipes have been removed to prevent future use

Any openings made to the tank for filling have been sealed.

Witnessed and certified by:



Steve L. Weaver
Underground Services Co. LLC