



# Davis Systems, Inc.

## Septic System Inspection Report

Date: 07-22-2025

Property Address - 14333 Kings Hwy., Montross, VA 22520

Inspection Date- 07-22-2025

### General Information

Locate, pump, and inspect septic system located at 14333 Kings Hwy, Montross, VA 22520.

### Condition of septic system

1-1000 gallon precast concrete septic tank located, pumped, and inspected. Septic tank is in good working condition. Outlet lid is broken. Precast concrete distribution box is deteriorated. 5 drainlines all taking water properly at the time of inspection.

### Disclaimer

In the event that any defect in the system is discovered in the future: the undersigned's liability shall not exceed foregoing inspection.

This inspection holds no guarantees, warranties, or liabilities. This inspection reflects present condition of the system.

### Comments

The septic system located at 14333 Kings Highway, Montross, Va 22520, was located, pumped, and inspected on 07-22-2025.

Wayne A. Davis, Jr  
Davis Systems, Inc