



Georgia Department of Public Health

On-Site Sewage Management System Inspection Report

PERMIT #: OSC15402722	DATE: 10/23/2025	COUNTY: White
PROPERTY ADDRESS #: THOMAS RD CLEVELAND, GA 30528	PROPERTY OWNER: BRIAN KILGORE	SEPTIC INSTALLER: Alexander, McKrae
	SUBDIVISION/LOT/BLOCK: TRACT 2/N/A/N/A	SEPTIC INSTALLER CERT #: 21749

Section A - General

DRINKING WATER SUPPLY: Public	STRUCTURE TYPE: Single-Family Residence	INSPECTION TYPE: New
WATER USAGE BY: Bedroom Numbers	# BEDROOMS / GPD: 4	LOT SIZE (SQ FT / ACRES): 1.37
PERC / LOADING RATE: 80	SOIL CLASSIFIER:	SOIL SERIES:

Section B - Primary / Pretreatment

PRETREATMENT METHOD: Septic Tank	RISER MANF: Not Applicable	GREASE TRAP MANF: Not Applicable
TANK CAPACITY (GALS): 1000	RISER MODEL: Not Applicable	GREASE TRAP MATERIAL: Not Applicable
TANK MATERIAL: Concrete	DOSING TANK MATERIAL: Not Applicable	GREASE TRAP CAPACITY (GALS):
TANK MANF: Parker Petroleum Company	DOSING TANK MANF: Not Applicable	AEROBIC TREATMENT UNIT MANF: Not Applicable
FILTER MANF: Polylok, Incorporated	DOSING TANK CAPACITY (GALS):	AEROBIC TREATMENT UNIT MODEL: Not Applicable
FILTER MODEL: PL- 68	PUMP INFO:	AEROBIC TREATMENT UNIT CAPACITY (GALS):

Section C - Secondary Treatment

ABSORPTION FIELD DESIGN: Serial	ABSORPTION FIELD PRODUCT: Quick 4 Plus High Capacity - 14	INSPECTED SQ FT: 732 INSPECTED LINEAR FT: 244
DEPTH OF TRENCHES (IN) MIN/MAX: 36 to 36	NUMBER OF TRENCHES:	DISTANCE B/W TRENCHES (FEET):
WIDTH OF TRENCHES (IN):		

Tips for Maintaining Your System

DO:	DON'T:
<ul style="list-style-type: none">Put only water, human waste, and toilet paper down the drains.Have tank pumped out every 3-5 years.Divert all water and gutters away from tank and drain lines.Spread out water usage (washing machine, showers, dishwasher).	<ul style="list-style-type: none">Pour fats, oils, or grease down any drain or toilet.Put kitchen scraps down the sink.Use the toilet as a trash can; no condoms, tampons, paper towels.Flush "flushable" wipes, they will clog your tank.Use additives or chemicals; they are NOT needed. Save your money for future pump outs.Plant, park, or build on top of your drain lines.

Note: Contact the Health Department for any additional inspections, documentation, or drawings for this property.

This inspection only captures items that were part of the above system, inspected on the above date.

An inspection for an on-site sewage management system, and subsequent approval of same by representatives of the County Board of Health shall not be construed as a guarantee that such systems will function satisfactorily for a given period of time; furthermore, said representatives do not, by any action taken in affecting compliance with these rules, assume any liability for damages which are caused, or which may be caused, by the malfunction of such system.

See second page for system drawing, remarks, approval status, and signature.

On-Site Sewage Management System Inspection Report (continued)

ADDRESS: THOMAS RD CLEVELAND, GA 30528	TANK SETBACKS MET: Yes	PERMIT #: OSC15402722
	ABSORPTION FIELD SETBACKS MET: Yes	SYSTEM APPROVAL STATUS: Approved
INSPECTOR & INSPECTOR TITLE: Sean Sullivan Environmental Health County Manager	SIGNATURE:	
REMARKS:		

System drawing not to scale

drawing8... 1 / 1

92%



FINAL APPROVAL

**APPLICATION FOR CONSTRUCTION PERMIT &
INSPECTION FORM FOR ON-SITE SEWAGE
MANAGEMENT SYSTEM**

PERMIT NUMBER: **OSC15402722**

Property Address: **THOMAS RD**
Owner's Name: **BRIAN KILGORE**
Builder/Company: **ZACH LURIE**
Water Supply: **PUBLIC**
Bedrooms: **3**
Gallons per Day: **15000**
Plumbing Level: **GROUND LEVEL**
Garbage Disposal: **NO**

Directions to Property:

Septic Tank Installer: McRae Alexander

Company Name: _____

Type System Installed: 15000 Linear Ft. 2400

FINAL APPROVAL

INSPECTION FORM FOR CONSTRUCTION PERMIT & MANAGEMENT SYSTEM

PERMIT NUMBER: OSC15402722
Property Address: THOMAS RD
Owner's Name: BRIAN KILGORE
Builder/Company: ZACH LURIE
Water Supply: PUBLIC
Bedrooms: 3
Gallons per Day:
Plumbing Level: GROUND LEVEL
Garbage Disposal: NO

WHITE COUNTY ENVIRONMENTAL HEALTH
1241 HELEN HWY, UNIT 210
CLEVELAND, GA 30528 ♦ (706) 348-7698
Type of Permit: NEW
Type of Facility: RESIDENTIAL
Subdivision:
Lot/Phase #: TRACT 2
Lot Size: 1.37
Perc Rate:
Soil Type:

Directions to Property:

Sketch is approximate * Sketch is not to scale *

Septic Tank Installer:

McRae Alexander

Certification #: _____

Company Name:

Expiration Date: _____

Type System Installed:

Tr. H.C. 4

Linear Ft.

Trench Width (in):

244

30'

Trench Depth (in):

36"

Septic Tank: 1000

Gallons

Manufacturer: Parker

Filter: polylock

Pump Tank: _____

Gallons

Grease Trap: _____

Gallons

Distance Septic Tank from Well/Well Site: N/A

Distance Drain Line from Well/Well Site: N/A

Final Approval By:

Date: 10-22-15

