



# Georgia Department of Public Health

## On-Site Sewage Management System Inspection Report

PERMIT #: <b>OSC15402721</b>	DATE: <b>10/23/2025</b>	COUNTY: <b>White</b>
PROPERTY ADDRESS #: <b>THOMAS RD CLEVELAND, GA 30528</b>	PROPERTY OWNER: <b>BRIAN KILGORE</b>	SEPTIC INSTALLER: <b>Alexander, McKrae</b>
	SUBDIVISION/LOT/BLOCK: <b>TRACT 1/N/A/N/A</b>	SEPTIC INSTALLER CERT #: <b>21749</b>

### Section A - General

DRINKING WATER SUPPLY: <b>Public</b>	STRUCTURE TYPE: <b>Single-Family Residence</b>	INSPECTION TYPE: <b>New</b>
WATER USAGE BY: <b>Bedroom Numbers</b>	# BEDROOMS / GPD: <b>4</b>	LOT SIZE (SQ FT / ACRES): <b>1.37</b>
PERC / LOADING RATE: <b>50</b>	SOIL CLASSIFIER:	SOIL SERIES: <b>Pacolet</b>

### Section B - Primary / Pretreatment

PRETREATMENT METHOD: <b>Septic Tank</b>	RISER MANF: <b>Not Applicable</b>	GREASE TRAP MANF: <b>Not Applicable</b>
TANK CAPACITY (GALS): <b>1000</b>	RISER MODEL: <b>Not Applicable</b>	GREASE TRAP MATERIAL: <b>Not Applicable</b>
TANK MATERIAL: <b>Concrete</b>	DOSING TANK MATERIAL: <b>Not Applicable</b>	GREASE TRAP CAPACITY (GALS):
TANK MANF: <b>Parker Petroleum Company</b>	DOSING TANK MANF: <b>Not Applicable</b>	AEROBIC TREATMENT UNIT MANF: <b>Not Applicable</b>
FILTER MANF: <b>Polylok, Incorporated</b>	DOSING TANK CAPACITY (GALS):	AEROBIC TREATMENT UNIT MODEL: <b>Not Applicable</b>
FILTER MODEL: <b>PL- 68</b>	PUMP INFO:	AEROBIC TREATMENT UNIT CAPACITY (GALS):

### Section C - Secondary Treatment

ABSORPTION FIELD DESIGN: <b>Serial</b>	ABSORPTION FIELD PRODUCT: <b>Quick 4 Plus High Capacity - 14</b>	INSPECTED SQ FT: <b>612</b>
DEPTH OF TRENCHES (IN) MIN/MAX: <b>38 to 38</b>	NUMBER OF TRENCHES:	INSPECTED LINEAR FT: <b>204</b>
WIDTH OF TRENCHES (IN):		DISTANCE B/W TRENCHES (FEET):

### Tips for Maintaining Your System

DO:	DON'T:
<ul style="list-style-type: none"><li>Put only water, human waste, and toilet paper down the drains.</li><li>Have tank pumped out every 3-5 years.</li><li>Divert all water and gutters away from tank and drain lines.</li><li>Spread out water usage (washing machine, showers, dishwasher).</li></ul>	<ul style="list-style-type: none"><li>Pour fats, oils, or grease down any drain or toilet.</li><li>Put kitchen scraps down the sink.</li><li>Use the toilet as a trash can; no condoms, tampons, paper towels.</li><li>Flush "flushable" wipes, they will clog your tank.</li><li>Use additives or chemicals; they are NOT needed. Save your money for future pump outs.</li><li>Plant, park, or build on top of your drain lines.</li></ul>

**Note: Contact the Health Department for any additional inspections, documentation, or drawings for this property. This inspection only captures items that were part of the above system, inspected on the above date.**

An inspection for an on-site sewage management system, and subsequent approval of same by representatives of the County Board of Health shall not be construed as a guarantee that such systems will function satisfactorily for a given period of time; furthermore, said representatives do not, by any action taken in affecting compliance with these rules, assume any liability for damages which are caused, or which may be caused, by the malfunction of such system.

**See second page for system drawing, remarks, approval status, and signature.**

## On-Site Sewage Management System Inspection Report (continued)

ADDRESS: <b>THOMAS RD CLEVELAND, GA 30528</b>	TANK SETBACKS MET: <b>Yes</b>	PERMIT #: <b>OSC15402721</b>
	ABSORPTION FIELD SETBACKS MET: <b>Yes</b>	<b>SYSTEM APPROVAL STATUS:</b>  <b>Approved</b>
INSPECTOR & INSPECTOR TITLE: <b>Sean Sullivan Environmental Health County Manager</b>	SIGNATURE:	
REMARKS:		

System drawing not to scale

drawing8... 1 / 1

92%



		<b>FINAL APPR</b>
<b>INSPECTION FOR CONSTRUCTION PERMIT &amp; INSPECTION FORM FOR ON-SITE SEWAGE MANAGEMENT SYSTEM</b>		
PERMIT NUMBER: <b>OSC15402721</b>		
Property Address: <b>THOMAS RD</b>		
Owner's Name: <b>BRIAN KILGORE</b>		
Builder/Company: <b>ZACH LURIE</b>		
Water Supply: <b>PUBLIC</b>		
Bedrooms: <b>3</b>		
Gallons per Day: <b>GROUND LEVEL</b>		
Plumbing Level: <b>NO</b>		
Garbage Disposal: <b>NO</b>		
Directions to Property:  Septic Tank Installer: <u><b>McRae Alexander</b></u>		
Company Name: _____  Type System Installed: <u><b>1100 ft</b></u> Linear Ft. <u><b>70 ft</b></u>		

# FINAL APPROVAL

## INSPECTION FORM FOR CONSTRUCTION PERMIT & MANAGEMENT SYSTEM

PERMIT NUMBER: OSC15402721  
Property Address: THOMAS RD  
Owner's Name: BRIAN KILGORE  
Builder/Company: ZACH LURIE  
Water Supply: PUBLIC  
Bedrooms: 3  
Gallons per Day:  
Plumbing Level: GROUND LEVEL  
Garbage Disposal: NO

WHITE COUNTY ENVIRONMENTAL HEALTH  
1241 HELEN HWY, UNIT 210  
CLEVELAND, GA 30528 ♦ (706) 348-7698  
Type of Permit: NEW  
Type of Facility: RESIDENTIAL  
Subdivision:  
Lot/Phase #: TRACT 1  
Lot Size: 1.37  
Perc Rate:  
Soil Type:

Directions to Property:

\*Sketch is approximate \*Sketch is not to scale

Septic Tank Installer:

McRae Alexander

Certification #:

Company Name:

Expiration Date:

Type System Installed:

Inf. H.C. 4

Linear Ft.

204

Trench Width (in):

36"

Trench Depth (in):

38"

Septic Tank: 1000 Gallons

Manufacturer: Parker

Filter: poly/lock

Pump Tank: — Gallons

Grease Trap: —

Gallons

Distance Septic Tank from Well/Well Site: N/A

Distance Drain Line from Well/Well Site: N/A

Final Approval By:

Date:

10-25-25

1  
4  
3  
1

