



U.S. DEPARTMENT OF ENERGY

THIS HOME'S SCORE 8 OUT OF 10

THIS HOME'S ESTIMATED ENERGY COSTS

\$1,701

PER YEAR

HOME PROFILE

LOCATION:

1952 NE 48th Way
Hillsboro, OR 97124

YEAR BUILT:

2007

HEATED FLOOR AREA:

1,587 sq.ft.

NUMBER OF BEDROOMS:

2

ASSESSMENT

ASSESSMENT DATE:

02/06/2026

SCORE EXPIRATION DATE:

02/06/2034

ASSESSOR:

Brian Denne
HealthyHabitat.org

PHONE:

503-330-1514

EMAIL:

Brian@
HealthyHabitat.org


CCB LICENSE #:

224451

Flip over to learn how to improve this score and use less energy!



Home Energy Score



Official Assessment | ID# 630449

The Home Energy Score is a national rating System developed by the U.S. Department of Energy. The Score reflects the estimated energy use of a home based upon the home's structure and heating, cooling, and hot water systems. The average score is a 5. Learn more at HomeEnergyScore.gov.


HOW MUCH ENERGY IS THIS HOME LIKELY TO USE?

Electric: 6,297 kWh/yr (\$0.18/kWh).....	\$1,145
Natural Gas: 376 therms/yr (\$1.48/therm).....	\$556
Other:	\$0
Solar Generation:	(\$0)
TOTAL ENERGY COSTS PER YEAR	\$1,701

How much solar energy does this home generate?

_____ kWh/yr

THIS HOME'S CARBON FOOTPRINT:



- Actual energy use and costs may vary based on occupant behavior and other factors.
- Estimated energy costs were calculated based on current utility prices in your area.
- Carbon footprint is based only on estimated home energy use. Carbon emissions are estimated based on utility and fuel-specific emissions factors provided by the OR Department of Energy.
- This report is valid for eight years from the assessment date. A free reprint of the report is available from us.greenbuildingregistry.com with updated utility and carbon information annually.
- **This report meets Oregon's Home Energy Performance Score Standard.**

Score today:

8

Score with priority improvements:

8

Estimated energy savings with priority improvements:

\$0 PER YEAR

Estimated carbon reduction with priority improvements:

0% PER YEAR

TACKLE ENERGY WASTE TODAY!

Enjoy the rewards of a comfortable, energy efficient home that saves you money.

- Get your home energy assessment. Done!
- Choose energy improvements from the list of recommendations below.
- Select a contractor (or two, for comparison) and obtain bids. If a new home, discuss with the builder. Checkout www.energytrust.org/findacontractor or call toll free **1-866-368-7878**.
- To find out more information about the state of Oregon Home Energy score program visit: oregon.gov/energy/home-energy-score
- Discover local incentives and learn more about Hillsboro's Home Energy Score Program at: Hillsboro-Oregon.gov/EnergyScore

PRIORITY ENERGY IMPROVEMENTS ¹

FEATURE	TODAY'S CONDITION ³	RECOMMENDED IMPROVEMENTS
---------	--------------------------------	--------------------------

ADDITIONAL ENERGY RECOMMENDATIONS ²

FEATURE	TODAY'S CONDITION ³	RECOMMENDED IMPROVEMENTS
Attic insulation	Ceiling insulated to R-35	Insulate to R-38 or R-49 if code requires it
Duct sealing	Un-sealed	Reduce leakage to a maximum of 10% of total airflow
Envelope/Air sealing	Not professionally air sealed	Professionally air seal
Air Conditioner	13.0 SEER	
Basement wall insulation	N/A	
Cathedral Ceiling/Roof	Roof insulated to R-30	
Duct insulation	Insulated	
Floor insulation	N/A	
Foundation wall insulation	Insulated to R-0	
Heating equipment	Natural gas furnace 92% AFUE	
Knee Wall insulation	Knee wall insulated to R-15	
Skylights	N/A	
Wall insulation	Insulated to R-15	
Water Heater	Natural gas EF 0.58	
Windows	Double-pane, low-E glass	
Solar PV	N/A	

1. To achieve the "Score with Priority Improvements" all recommended improvements in the Priority Energy Improvements section must be completed. All together, these priority improvements have a simple payback of ten years or less.

2. Additional energy efficiency improvements may take longer than ten years to make a return on investment but can have a significant impact on the comfort, efficiency and environmental impact of your home.

3. Today's Condition represents the majority condition for that feature in the home. Additional energy efficient features may be present in the home and not accounted for in this report. Trees and other features may provide additional energy efficiency benefits to the building.