Form 238-7
7/94

POSTED

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

RECEIVED
Use Typewriter or Ball Point Pen
APR 24 1995
NORTHERN REGION
IDWR

95-95-N-0036-000

1. DRILLING PERMIT NO. 95 - 95 - N - 0036 - 000
Other IDWR No.

2. OWNER:
Name TAGGART, JOE
Address E 4925 BOEKEL ROAD
City RATHDRUM State ID Zip 83858

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S — X

Twp. 51 North ☒ or South ☐
Rge. 03 East ☐ or West ☒
Sec. 04 , ____ 1/4 NE 1/4 NE 1/4
10 acres 40 acres 160 acres
Gov't Lot ____ County KOOTENAI

Address of Well Site
City
(Give at least name of road + Distance to Road or Landmark)

Lt. 001 Blk. 001 Sub. Name HAYDEN ACRES

4. PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK
☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
BENTONITE	0	110	2 SACKS	POWDER
BENTONITE	0	110	2 SACKS	CRUMBLES

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s)
Was drive shoe seal tested? Y ☐ N ☒ How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	185	.250	STEEL	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS
☒ Perforations Method TORCH CUT
☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
165	185	1/16	60	6	STEEL	☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
100 ft. below ground Artesian pressure ____ lb.
Depth flow encountered ____ ft. Describe access port or control devices:

NENE 4 51N 3W

11. WELL TESTS:
☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
25+			2 HRS

Water Temp. COLD Bottom hole temp.
Water Quality test or comments: GOOD & CLEAN

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
8	0	1	TOPSOIL BROWN SOFT		X
8	1	41	CLAY TAN BROWN MED.		X
8	41	110	CLAY TAN YELLOW MED		X
8	110	158	BASALT BLACKISH HARD		X
8	158	168	BASALT BLACKISH FRACTURED	X	
8	168	180	BASALT BLACKISH HARD		X
8	180	185	CLAY BLACK SOFT		X
			1x6" Well Seal - Bolt On		
			3/8 Pea Gravel From 100'-185'		

Completed Depth 185 (Measurable)
Date: Started 04/12/95 Completed 04/12/95

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WELL SERVICE, INC. Firm No. 448

Firm Official [signature] Date 04/19/95
and
Supervisor or Operator [signature] Date 04/19/95
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES