



Pump Installation Report

REPORT # _____
(Department Use Only)

CERTIFIED PUMP INSTALLER

Certificate # 887
Name Mark Verge
Company Aim Pumps
Address Waverley
Phone 902 433 -0810

PUMP INSTALLATION LOCATION

Owner of Well _____
Contractor/Builder/Consultant Highmark Homes
Civic Address of Well 101 Orchid
Subdivision & Lot # of Well Indigo Shores
Community Sackville County Halifax
Postal Code _____ Phone _____

PUMPING EQUIPMENT

☒ New ☐ Replacement ☐ Other
Pump Make Webtrol
Pump Model WT0715
Motor Make Faradyne
☐ 2 Wire ☒ 3 Wire
Motor Size 1 1/2 ☒ HP / ☐ KW 3ph
Voltage 230 Volt

TYPE OF PUMP

☐ Jet
☒ Submersible
☐ Other (specify) _____

OPERATING PRESSURE RANGE

Low 0 psi High 60 psi

INSTALLATION DETAILS

Well Diameter 6 inches
Well Depth 460 feet
Static Level (from surface) 10 feet
Depth of pump 440 feet
RISER PIPE: Material 1" CSA Poly
Pressure Rating 200 psi
Torque Arrester ☒ Yes ☐ No
Pitless Adapter ☒ Yes ☐ No
Make A.G. Model AT800
Storage Tank Model V15
Total Capacity 1.5 ☒ gal / ☐ L
Draw Off Capacity at Operating Pressure 1 ☒ gal / ☐ L
Well Chlorinated ☒ Yes ☐ No

WATER SYSTEM USE

☒ Domestic ☐ Irrigation
☐ Industrial ☐ Public Supply
☐ Commercial ☐ Agricultural
☐ Municipal ☐ Heat Pump
☐ Other (specify) _____

SOURCE OF WELL YIELD DATA

Well Log # (if known) _____
☐ Pump Test ☐ Owners' Information
☐ Estimated by ☐ Other

COMMENTS BY INSTALLER

CERTIFICATION:

I certify this well has been constructed in accordance with the Nova Scotia Environment Act and Well Construction Regulations.

Date Pump Installed May 24/26 Signature of License Holder [Signature] Date Signed June 8/26

Mail to: Nova Scotia Department of Environment
30 Damascus Road, Suite 115
Bedford, Nova Scotia B4A 0C1